

Kansas Administrative Regulations

Department of Labor

Article 51.—High Pressure Boilers

49-51-4. Cast iron headers and mud drums.

The maximum allowable working pressure on a water tube boiler with tubes which are secured to cast iron or malleable iron headers or which have cast iron mud drums shall not exceed 160 psig.

(Authorized by and implementing K.S.A. 1985 Supp. 44-916; effective May 1, 1987.)

***** Authenticated Kansas Administrative Regulation *****