

Kansas Administrative Regulations

Department of Labor

Article 51.—High Pressure Boilers

49-51-12. Repairs and renewals of boiler and pressure vessel fittings and appliances.

If repairs are made to any fittings or appliances of a boiler or pressure vessel or if it becomes necessary to replace them, the repairs or replacements shall meet the provisions of the following standards:

- (a) ASME code sections I and VIII, as adopted in K.A.R. 49-45-1, K.A.R. 49-45-29, K.A.R. 49-45-30, and K.A.R. 49-45-31;
- (b) ASME B 31.1, as adopted in K.A.R. 49-45-28;
- (c) ASME CSD-1, as adopted in K.A.R. 49-45-27;
- (d) NFPA sections 85, 85A, 85F, and 86, as adopted in K.A.R. 49-45-37, K.A.R. 49-45-38, K.A.R. 49-45-39, K.A.R. 49-45-40; and
- (e) the national board inspection code, as adopted in K.A.R. 49-45-20.

(Authorized by and implementing K.S.A. 44-916; effective May 1, 1987; amended April 28, 2000; amended Nov. 3, 2006.)

***** Authenticated Kansas Administrative Regulation *****