

Kansas Administrative Regulations

Department of Health and Environment

Article 19.—Ambient Air Quality Standards and Air Pollution Control

28-19-713a. Emission limitation requirements.

No owner or operator subject to K.A.R. 28-19-713 shall allow any emission unit to emit nitrogen oxides in excess of the following emission limitations based on a 30-day rolling average:

(a) From electric generating units, for the purposes of K.A.R. 28-19-713 through K.A.R. 28-19-713d, the following:

(1) 0.26 pounds per million British thermal units (lbs/MMBtu) for unit 1, a turbo wall-fired Riley Stoker boiler located at the Nearman Creek power station in Kansas City, Kansas; and

(2) 0.20 lbs/MMbtu for unit 2, a wall-fired Riley Stoker boiler located at the Quindaro power station in Kansas City, Kansas; and

(b) from flat glass furnaces, 7.0 pounds per ton of glass produced.

(Authorized by K.S.A. 2009 Supp. 65-3005; implementing K.S.A. 65-3010; effective June 25, 2010.)

***** Authenticated Kansas Administrative Regulation *****