

Kansas Administrative Regulations

Department of Labor

Article 52.—Low Pressure Heating Boilers

49-52-12. Return pump.

Each boiler equipped with a condensate return pump shall be provided with a water level control arranged to automatically maintain the water level in the boiler within the range of the gauge glass.

(Authorized by and implementing K.S.A. 1985 Supp. 44-916; effective May 1, 1987.)

***** Authenticated Kansas Administrative Regulation *****