

Kansas Administrative Regulations

State Fire Marshal

Article 8.—Liquefied Petroleum Gases

22-8-2. Required signs at liquefied petroleum gas facilities.

Each owner or operator of a liquefied petroleum gas facility shall ensure that the requirements of this regulation are met. (a) Each bulk storage container for liquefied petroleum gas shall be marked with "Flammable LP gas" in letters at least six inches in height. A "No smoking" sign shall be posted within 20 feet of the container area.

(b) A weatherproof sign shall be posted at the main entrance to the facility stating the owner's name, the address of the facility, the license number of the facility, and an emergency phone number, which shall be answered 24 hours a day and seven days a week. The owner or operator, or designee, shall be available for emergency callback. This sign shall be readable at all times and shall be marked with letters and numbers at least three inches in height.

(Authorized by and implementing K.S.A. 2004 Supp. 55-1812; effective May 1, 1979; amended May 1, 1984; amended March 31, 2006.)

***** Authenticated Kansas Administrative Regulation *****