

Kansas Administrative Regulations

Department of Labor

Article 52.—Low Pressure Heating Boilers

49-52-18. Hot water supply boilers.

(a) No hot water supply boiler or commercial or domestic type of water heater of any size shall be used for any type of comfort heat. This prohibition shall include floor heat and closed-loop hot water heating systems of any kind. Each boiler that is used for heating purposes and is not made of cast iron shall be code-stamped and registered with the national board of boiler and pressure vessel inspectors.

(b) No hot water heating system shall be connected with any domestic hot water system or be used in combination as a building heating system and domestic hot water system.

(c) No hot water supply boiler code-stamped "HLW" shall be used for any kind of comfort heat.

(d) For the purposes of each boiler certification inspection, when a hot water supply boiler is connected to a hot water supply tank, this combination shall be considered one unit.

(e) Each hot water supply boiler that requires electricity to power burners, to stack dampers, or to start an electronic ignition shall be hardwired into the facility's electrical system.

(Authorized by and implementing K.S.A. 44-916; effective Nov. 3, 2006.)

***** Authenticated Kansas Administrative Regulation *****