

Kansas Administrative Regulations

Department of Labor

Article 50.—General Requirements for All Boilers

49-50-23. Certificate of inspection.

The current certificate of inspection for each stationary boiler shall be posted under a clear covering on the boiler room wall in a conspicuous location. The current certificate of inspection for each portable boiler shall be attached to the boiler. A utility power plant's certificate current certificate of inspection shall be posted under a clear covering in the control room of the utility power plant or another suitable location accessible to the inspector.

(Authorized by K.S.A. 44-916; implementing K.S.A. 44-924; effective Nov. 3, 2006.)

***** Authenticated Kansas Administrative Regulation *****