

Kansas Administrative Regulations

Department of Labor

Article 52.—Low Pressure Heating Boilers

49-52-14. Repair and replacement of fittings and appliances.

(a) If repairs are made to fittings or appliances or if it becomes necessary to replace them, the repairs shall meet the following standards:

(1) Sections I, IV, and VIII of the ASME code for new construction, as adopted in K.A.R. 49-45-1, K.A.R. 49-45-5, K.A.R. 49-45-29, K.A.R. 49-45-30, and K.A.R. 49-45-31;

(2) ASME CSD-1, as adopted in K.A.R. 49-45-27;

(3) NFPA 85, 85A, 85F, and 86, as adopted in K.A.R. 49-45-37 through K.A.R. 49-45-40; and

(4) the national board inspection code, as adopted in K.A.R. 49-45-20.

(b) Each electrical control and each safety device shall bear a label and shall be listed by a nationally recognized agency, including UL (underwriters laboratories), FM (factory mutual), or AGA (American gas association), and shall bear an identification label from one of these agencies.

(Authorized by and implementing K.S.A. 44-916; effective May 1, 1987; amended April 28, 2000; amended Nov. 3, 2006.)

***** Authenticated Kansas Administrative Regulation *****