

Kansas Administrative Regulations

Department of Labor

Article 51.—High Pressure Boilers

49-51-2. Maximum allowable working pressure for standard boilers and pressure vessels.

The maximum allowable working pressure for standard boilers and pressure vessels shall be determined in accordance with the applicable provisions of the edition of the ASME code under which they were constructed and stamped.

(Authorized by and implementing K.S.A. 1998 Supp. 44-916; effective May 1, 1987; amended April 28, 2000.)

***** Authenticated Kansas Administrative Regulation *****