

Kansas Administrative Regulations

Kansas Department of Agriculture

Article 27.—Lodging Establishments

4-27-8. Guest and public safety.

(a) If the secretary has reason to believe that defects could be present with regard to the integrity of the structure or electrical system of the lodging establishment, the licensee may be required by the secretary to retain the services of a professional engineer or local building code officer to certify the lodging establishment for building safety. Disasters after which the structural integrity may need to be evaluated shall include a heavy snow or ice storm, flood, tornado, straight-line winds, fire, hurricane, and earthquake.

(b) Each licensee shall ensure that all repairs, construction, renovations, and maintenance are conducted in a manner that provides safe conditions for the guests and the public.

(c) The licensee of each lodging establishment using fuel-fired equipment or appliances that pose a potential carbon monoxide risk, including lodging establishments with attached parking garages or wood-burning fireplaces, shall install one or more carbon monoxide detectors according to the manufacturer's specifications.

(1) A carbon monoxide detector shall be required in each non-guest room adjoining or sharing a common ventilation system with an attached parking garage.

(2) Each carbon monoxide detector shall be in working condition.

(A) Each carbon monoxide detector shall be tested at least every six months to ensure that the detector is operating properly. The batteries shall be changed, as needed.

(B) A 12-month history of all test results shall be logged and maintained at the lodging establishment and made available to the secretary upon request.

(C) If a battery-operated detector is not operational for two consecutive tests, the licensee shall install a detector that is hardwired with a battery backup.

(3) A carbon monoxide detector shall not be required to be installed in an attached parking garage area.

(d) The operation and maintenance requirements for each lodging establishment shall include all of the following:

(1) Each lodging establishment shall meet the requirements of all applicable building codes, fire codes, and ordinances.

(2) No freshly cut Christmas trees or boughs shall be used unless the freshly cut trees or boughs are treated with a flame-resistant material. The documentation of the treatment shall be kept on file at the lodging establishment for at least one year.

(3) Textile materials having a napped, tufted, looped, woven, nonwoven, or similar surface shall not be applied to walls or ceilings, unless the textile materials are treated with a flame-resistant material. The documentation of the treatment shall be kept on file at the lodging establishment for as long as the materials are used on the walls or ceilings. This documentation shall be made available to the secretary upon request. Carpeting used as coving that covers the junction between the floor and walls shall be exempt from this requirement.

(4) Foam or plastic materials or other highly flammable or toxic material shall not be used as an interior wall, ceiling, or floor finish unless approved by the secretary.

(5) The doors in any public areas that lead outside the lodging establishment shall not be locked or blocked, preventing egress when the building is occupied. No exit doors shall be concealed or obscured by hangings, draperies, or any other objects.

(6)(A) Portable fire extinguishers shall be required and located in the hallways, mechanical rooms, laundry areas, and all other hazardous areas and within 75 feet of each guest room door. All portable fire extinguishers shall be easily accessible to the guests and employees.

(B) Each fire extinguisher shall meet the following requirements:

- (i) Be maintained in a fully charged and operable condition;
- (ii) be rated at least 2A-10BC;
- (iii) contain at least five pounds of fire suppressant; and

(iv) be inspected annually by a fire extinguisher company, a fire department representative, or another entity approved by the secretary. The licensee shall retain a record of these inspections at the lodging establishment for at least one year.

(7) Emergency lighting shall be provided where guest room doors open to an interior corridor and where guest room doors open to the outside but not directly at ground level.

(8) A smoke detector shall be installed in each guest sleeping room, cooking area and kitchen, interior stairwell, hallway, laundry area, mechanical room, and any other fire hazard area. Any heat-sensing device designed to detect fire may be installed in a cooking area in lieu of a smoke detector.

(A) All smoke detectors and heat-sensing devices shall be maintained in operating condition.

(B) Each smoke detector and each heat-sensing device shall be tested at least every six months to ensure that the detector or device is operating properly. The batteries shall be replaced as needed.

(C) A 12-month history of test results shall be logged and maintained at the lodging establishment and made available to the secretary upon request.

(D) If a battery-operated detector is not operational for two consecutive tests, the licensee shall install a detector that is hardwired with a battery backup.

(E) Smoke detectors for hearing-impaired individuals shall be available as specified in K.S.A. 36-517, and amendments thereto.

(9) If hardwired, interconnected smoke detectors are used, these detectors shall be tested and approved annually by a fire sprinkler company, fire alarm company, fire department representative, or any other entity approved by the secretary. A 12-month history of test results shall be maintained at the lodging establishment and made available to the secretary upon request.

(10) If fire alarm systems and fire sprinkler systems are used, the systems shall be tested and approved annually by a fire alarm company, fire sprinkler company, fire department representative, or any other entity approved by the secretary. A 12-month history of test results shall be maintained at the lodging establishment and made available to the secretary upon request.

(11)(A) All exit signs shall be clean and legible. At least one exit sign shall be visible from each of the following locations:

- (i) The doorway of each guest room that opens to an interior corridor; and
- (ii) the doorway of each guest room that opens to the outdoors but not directly at ground level.

(B) Each newly constructed lodging establishment shall have supplemental directional signs indicating the direction and path of egress.

(C) Boarding houses and rooming houses shall not be required to have exit signs if the requirements in paragraphs (d)(5) and (12) are met.

(12) An evacuation route diagram shall be posted in a conspicuous location in each guest room. The diagram shall include the location of the guest room, the layout of the floor, and the location of the nearest available exits. If the door of a guest room opens directly to the outdoors at ground level, the diagram shall not be required to be posted.

(13) A copy of an emergency management plan and employee instructions shall be kept on file in the lodging establishment, made accessible to all employees, and made available to the secretary upon request. A record that each employee has received training on the emergency management plan shall be maintained at the lodging establishment in each employee's file.

(Authorized by and implementing K.S.A. 2011 Supp. 36-506, as amended by L. 2012, ch. 145, sec. 6; effective June 4, 2010; amended Feb. 8, 2013.)

***** Authenticated Kansas Administrative Regulation *****