Kansas Administrative Regulations

Department of Health and Environment

Article 29.—Solid Waste Management—Part 9. Standards for the Management of Household Hazardous Waste.

28-29-1101. Household hazardous waste facility design.

The owner or operator of each HHW facility shall perform the following:

(a) Design and construct each access road to accommodate expected traffic flow in a safe and efficient manner;

(b) construct the floor or base of each household waste receiving area and each processing area of concrete or asphalt;

(c) design and construct each storage area for household waste, except used oil stored in tanks, with a weather-resistant, permanent roof; and

(d) provide secondary containment for all HHW stored for disposal or recycling. The secondary containment shall be capable of containing either 110 percent of the volume of the largest container or 10 percent of the total volume of all the containers, whichever is greater.

(Authorized by and implementing K.S.A. 1999 Supp. 65-3406 and 65-3460; effective June 16, 2000.)

***** Authenticated Kansas Administrative Regulation *****