

Kansas Administrative Regulations

Department of Labor

Article 50.—General Requirements for All Boilers

49-50-3. Boiler combustion chamber vents.

Each boiler shall be equipped with vents to convey the products of combustion safely from the boiler furnace to the outside atmosphere. Flue piping, draft hoods, draft diverters, and chimney connections shall be installed according to the boiler manufacturer's instructions and the provisions of the national fire codes NFPA 31, "standard for the installation of oil-burning equipment," and NFPA 54, "national fuel gas code," as adopted by reference in K.A.R. 49-50-2.

(Authorized by and implementing K.S.A. 44-916; effective May 1, 1987; amended April 28, 2000; amended Nov. 3, 2006.)

***** Authenticated Kansas Administrative Regulation *****