

Kansas Administrative Regulations

Department of Labor

Article 52.—Low Pressure Heating Boilers

49-52-19. Pool heaters.

(a) Each pool heater shall have the following controls and safety devices that meet the following requirements:

(1) A safety relief valve, with a set pressure not to exceed the maximum allowable working pressure of the lowest rated component in the system; and

(2) a pressure switch or a flow switch that prevents the burner from operating if the circulating pump is not in operation and that maintains adequate temperature controls conforming to the generally acceptable standards for pool heaters.

(b) Each pool heater that can generate at least 400,000 BTUH shall be constructed to meet the requirements of ASME section IV, as adopted by reference in K.A.R. 49-45-5, and shall be registered with the national board. Each pool heater shall be equipped with the controls and safety devices required for heating boilers.

(Authorized by and implementing K.S.A. 44-916; effective Nov. 3, 2006.)

***** Authenticated Kansas Administrative Regulation *****