

Kansas Administrative Regulations

Department of Labor

Article 52.—Low Pressure Heating Boilers

49-52-16. Provisions for thermal expansion in hot water supply systems.

If the system is equipped with a check valve or pressure-reducing valve in the cold water inlet line, an airtight expansion tank or other suitable air cushion shall be used. If provided, the tank shall be constructed according to the requirements of section VIII, division 1 of the ASME code, with a maximum allowable working pressure to equal or exceed the working pressure of the hot water supply boiler.

(Authorized by and implementing K.S.A. 1998 Supp. 44-916; effective April 28, 2000.)

***** Authenticated Kansas Administrative Regulation *****