

Kansas Administrative Regulations

Department of Labor

Article 52.—Low Pressure Heating Boilers

49-52-4. Nonstandard cast iron boilers.

(a) The maximum allowable working pressure of a nonstandard boiler composed principally of cast iron shall not exceed 15 psig for steam service or 30 psig for hot water service.

(b) The maximum allowable working pressure of a nonstandard boiler having cast iron shell or heads and steel or wrought iron tubes shall not exceed 15 psig for steam service or 30 psig for hot water service.

(Authorized by and implementing K.S.A. 1985 Supp. 44-916; effective May 1, 1987.)

***** Authenticated Kansas Administrative Regulation *****