

Kansas Administrative Regulations

Kansas Department of Agriculture—Division of Water Resources

Article 3.—Appropriation Rights

5-3-5c. Check valves.

(a) All diversion works not subject to regulation under the Kansas chemigation safety law, K.S.A. 2-3301 et seq. and amendments thereto, into which any type of chemical or other foreign substances will be injected into the water pumped from the diversion works shall be equipped with an in-line, automatic, quick-closing check valve capable of preventing pollution of the source of the water supply.

(b) Each check valve required by the chief engineer shall be constructed and installed in accordance with the requirements specified in K.A.R. 5-6-13a.

(c) Each check valve and all required components shall be maintained in an operating condition that prevents backflow into the source of water supply whenever a foreign substance could reasonably be expected to be introduced into the water system. (Authorized by K.S.A. 82a-706a; implementing K.S.A. 82a-706, K.S.A. 82a-706a, K.S.A. 82a-712; effective May 1, 1980; amended May 1, 1981; amended Oct. 24, 2003.)

***** Authenticated Kansas Administrative Regulation *****