

# **Kansas Administrative Regulations**

## **State Fire Marshal**

### **Article 7.—Flammable And Combustible Liquids**

#### **22-7-11. Connection of above ground tanks to dispensers used for refueling vehicles.**

(a) Above ground tanks of no more than 12,000 gallons total capacity may be connected to a dispenser used for refueling vehicles if, by the determination of the state fire marshal, adequate safeguards, including distances to property of value, proper valving and dispenser protection are provided and a reasonable degree of safety is maintained.

(b) Local jurisdictions may supersede this approval through zoning, ordinance or permitting prohibitions against such installations.

#### **Editor's Note:**

This article was formerly entitled, "Bulk Oil and Service Stations; Flammable Liquids." Regulations formerly appearing hereunder were revoked.

(Authorized by and implementing K.S.A. 1991 Supp. 31-133; effective May 10, 1993.)

\*\*\*\*\* Authenticated Kansas Administrative Regulation \*\*\*\*\*