

Kansas Administrative Regulations

Department of Labor

Article 50.—General Requirements for All Boilers

49-50-12. Reinstalled boiler or pressure vessel.

When a stationary boiler or pressure vessel is moved and reinstalled, it shall be brought up to code and shall be subject to immediate certification inspection upon reinstallation. The owner, user, or installer shall notify the chief inspector of the reinstallation. However, a pressure vessel shall not require inspection if moved to a different location or reinstalled by the same owner.

(Authorized by K.S.A. 1998 Supp. 44-916; implementing K.S.A. 1998 Supp. 44-917; effective May 1, 1987; amended April 28, 2000.)

***** Authenticated Kansas Administrative Regulation *****