

Kansas Administrative Regulations

Department of Labor

Article 50.—General Requirements for All Boilers

49-50-13. Reinstalled boiler or pressure vessel at same location.

If a boiler or pressure vessel located in this state is moved for temporary use or repair, it shall be subject to immediate certification inspection upon reinstallation. The reinstalled boiler or pressure vessel shall be brought up to the current code requirements. The boiler or pressure vessel shall have a certification inspection if the boiler or pressure vessel has not been previously registered. The owner, user, or installer shall notify the chief inspector of the reinstallation.

(Authorized by K.S.A. 44-916; implementing K.S.A. 44-917; effective May 1, 1987; amended April 28, 2000; amended Nov. 3, 2006.)

***** Authenticated Kansas Administrative Regulation *****